



HYGIENE CERTIFICATE

Nr: 590230019

SWISS KRONO sp. z o.o.
ul. Serbska 56
68-200 Żary, Poland

CERTIFICATE HOLDER

SWISS KRONO sp. z o.o.
ul. Serbska 56
68-200 Żary, Poland

MANUFACTURER

HPL BE.VELVET antifingerprint

PRODUCT NAME

TRADE NAME: SWISS KRONO HPL BE.VELVET antifingerprint

THICKNESS: 0,4-0,8 MM

use of the product in:

- **rooms category A***: residential and also intended for permanent stay of patients, rooms for children and adolescents in education buildings and food storage rooms - the material load should not exceed the value of **8.3 m²/m³**.
- **rooms category B***: in public utility buildings other than the above-mentioned and auxiliary rooms in flats - the material load should not exceed **16.6 m²/m³**.

Recommendations: the rooms containing the products covered by the certificate should be ventilated until the odor disappears.

*categories of rooms in accordance with the Regulation of the Minister of Health and Social Welfare of 1996.03.12, No. 19, item 231.

Hygiene class: **E1**, as required: **≤0.124 mg/m³** on the basis of the report **11968-58-2023**

Research & Development Centre of Wood-Based Panels Testing Laboratory, Laboratory for Testing Products,
ul. Mickiewicza 10a, 83-262 Czarna Woda

MODEL / TYPE / DESCRIPTION

2023.03.23

DATE OF ISSUE

2024.03.22

EXPIRATION DATE

Marta Wroblec

CERTIFICATION MANAGER



Warsaw, 2023.03.23

GREEN ANGEL Sp. z o.o., ul. Senatorska 18a, 00-082 Warsaw, Product Certification Body, www.green-angel.pl

The certificate applies only the products having identical characteristics as the test sample and complies the requirements given above.